

Island County Water Well Information



WellKey: GPG

General Information

Owner Name (log): Jack Grady

DOE Tag: AGA981

DOE NOI:

DOE ID

65456

Well Address: 1050' S. & 180' W. from Ctr Sec 24

Well Parcel: [R03224-203-3710](#)

Served Parcel:

Horiz/Vert Accuracy: GPS / DEM

Site Type: Well

USGS ID: [481503122441801](#)

SWI Rating: Very-High Risk



Construction Information

Construction Date: 03/13/79

Driller Name: Whidbey Well Drillers (Faber)

LS Elevation: 223 ft. MSL

Depth Well: 283 ft.

TD Elevation: -60 ft. MSL

WL Measurements: [2 measurements \(Click to View\)](#)

WL Elevation: 0 ft. MSL



Water Quality Information

Water Samples: [58 samples \(Click to View\)](#)


Avg/Med/Max Arsenic: 0.003 / 0.00325 / 0.005 mg/l

Avg/Med/Max Chloride: 99.87 / 96 / 179 mg/l

Avg/Med/Max Hardness: 384.80 / 410 / 437 mg/l

Avg/Med/Max Nitrate: 0.22 / 0.25 / 0.25 mg/l

Bacteria Samps (distribution): [327 samples \(Click to View\)](#)



Public Water System Information


Pws Name: Seawest Water System

PwsID: [37544](#)

Approved Connects: 28

Pws Source #: SO# 1

Pws Source Name: AGA981 WELL



Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.
Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/31/2020